

Addendum No. 01

Date: July 15, 2016

Project: Renovate Inpatient SCI Suite #541-16-106

Location: VAMC Wade Park 10701 East Blvd. Cleveland, OH 44106

Documents: May 10, 2016

This Addendum hereby modifies, supplements, and amends the bidding documents, as prepared by Perspectus Architecture, for all labor, material, and equipment of every nature and required for the execution of the entire work for the above referenced project. Wherein this Addendum varies or is in conflict with the Bidding Documents, the requirements of this Addendum shall govern. In all other particulars, the requirements of the original Specifications and Bidding Documents, including any previous Addenda, shall govern.

This Addendum includes the following Attachments:

Drawing 1-01.3 – Life Safety Plan – Phase 3

Drawing 1-03.3 – Demolition Plans – Phases 4 & 5

Drawing 1-03.4 - Demolition Plans – Phases 6A & 6B

Drawing 1-03.5 - Demolition Plans – Phases 7A & 7B

Drawing 1-06.3 - Headwall Plans, Sections, Elevations and Details

Drawing 1-E0.1 – Lighting Fixture Schedule

Drawing 1-E2.1 – Partial Sixth Floor Lighting Plans – Phases 1B, 2, 3 & 5

This Addendum includes the following Item:

Item 1 Drawing 1-01.3

- A. Revised Room Name for 6B101.

Item 1 Drawings 1-03.3, 1-03.4, 1-03.5

- A. Added Key Note 18 and references to Plans regarding removing and reinstalling window treatments/shades.

Item 1 Drawing 1-06.3

- A. All voids in patient headwalls shall be filled with non-combustible mineral fiber.

Item 2 Drawing 1-E0.1

- A. Added lighting fixture images to lighting fixture schedule.
- B. Modified driver type of fixture type E.
- C. Added manufacturer and model to fixture types E, F1 and F2.
- D. Modified lighting installation note L5.
- E. Removed fixture type F.

Item 1 Drawing 1-E2.1

- A. Changed fixture type from type F to type L.

END OF ADDENDUM NO. 01